



3829 Forest Parkway, Suite 500  
Wheatfield, NY USA

Phone: (716) 629-3800  
FAX: (716) 693-9162



### Certificate of Compliance

The following product, with the options of KA, KB, KC, KD, KE, KF:

780

has been evaluated and tested too the following requirements and found to comply with them.

ANSI/ISA-12.12.01-2007, CSA C22.2 No.213-M1987, UL 913: 2008, CAN/CSA No. 60079-0:07,  
CAN/CSA No. E60079-11:02, UL 1203:2006, CAN/CSA C22.2 No. 60079-1:07, FM3600:1998,  
FM3615:2006, CSA C22.2 No. 94-1-07, UL 50:2007, CSA C22.2 No. 94.2-07, UL 50E:2007,  
ANSI/ISA 12.27.01:2003

The product will be marked with the ETL logo to show compliance with these standards.

For intrinsically safe installations, options KB and KE, it must be installed per CD0670.

The Intertek [Authorization To Mark for Report 3186591CRT-004](#).

I, the undersigned, declare the above product meets the standards that are listed above.

\_\_\_\_\_  
Bruce R. Temple  
Certification/Regulation Lead

January 24, 2012  
Date