



199 Fire Tower Drive
Tonawanda, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the KH option:
511, 512, 513

Comply with the following IECEx standards:

IEC 60079-0: 2011 (Edition 6.0),
IEC 60079-11: 2011 (Edition 6.0),

IECEx Certificate No: [IECEX FMG 15.0002](#)

This report shows that these products are Intrinsically Safe and can be used in the following Hazardous Locations:

Ex ia IIC T4/T5

Temperature Code T4: $-40^{\circ}\text{C} \leq T_a \leq +85^{\circ}\text{C}$

Temperature Code T5: $-40^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$

When installed per drawing: [CD0671](#)

The product also has an IP68 rating

The products are marked with the IECEx Certificate Number and the above ratings

I declare the above products meet the essential requirements that are specified above.

3/29/2018

Joel Neri
Viatran Quality/Approvals Manager

Date