



199 Fire Tower Drive  
Tonawanda, NY USA

Phone: (716) 629-3800  
FAX: (716) 693-9162



## EU Declaration of Conformity

The following models, with the NK option:

**510 and 520**

Comply with the following EU Directives

EMC Directive 2014/30/EU

EN 61326-1:2013

EN 55011:2009+A1:2010

EN 61000-4-2:2009

EN 61000-4-3:2006+A2:2010

EN 61000-4-4:2012

EN 61000-4-5:2014

EN 61000-4-6:2014

ATEX Directive 2014/34/EC

EN 60079-0: 2012

EN 60079-11: 2012

EU-Type Examination Certificate Number: Presafe 16 ATEX 8465X

This shows that these products are Intrinsically Safe and can be used in the following  
Hazardous Locations:

 **II 1 G Ex ia IIC Ga**

Temperature Code T4:  $-20^{\circ}\text{C} \leq T_a \leq +80^{\circ}\text{C}$

Temperature Code T5:  $-20^{\circ}\text{C} \leq T_a \leq +40^{\circ}\text{C}$

When installed per drawing: CD0666

Notified Body      Det Norske Veritas Certification AS  
Veritasveien 1  
1363 HØVIK, Norway

PED 2014/68/EU

Viatran Corporation's evaluation of conformity to the PED Directive, Category 1, based on a  
Module A assessment. This applies to all transmitters listed above for Maximum Working  
Pressure ranges equal to or greater than 200 bar (2900 PSI).

RoHS 2011/65/EU

This product is RoHS compliant.

The products are marked with the CE Mark and the above ratings

I declare the above products meet the essential requirements that are specified above.

  
Joel Neri  
Viatran Quality/Approvals Manager

10/3/2017  
Date