



199 Fire Tower Dr  
Tonawanda, NY 14150 USA

Phone: (716) 629-3800  
FAX: (716) 693-9162



## Certificate of Compliance

The following models, with the NX option:

**570, 571, 572, 584, 970**

Were evaluated by:

CSA International  
8501 E. Pleasant Valley Road  
Cleveland, OH 44131

They were found to comply with the following Canadian Regulations:

CAN/CSA Standard C22.2 No. 0- M91 (Reaffirmed 2001)  
CSA Std C22.2 No. 25- 1966  
CSA Std C22.2 No 30-1986  
CAN/CSA- C22.2 No. 94-M91  
CSA Std C22.2 No. 142- M1987  
CAN/CSA- C22.2 No 157- 92  
CSA Std C22.2 No. 1010-1- 1992  
CSA Std C22.2 No. 1010.1B- 97  
TIL No. I-29B  
CAN/CSA—E79-0:95  
CAN/CSA—E79-11:95  
ANSI/ISA 12.27.01-2011

This shows that these products are Intrinsically Safe and can be used in the following Hazardous Locations:

**Class I, Division 1, Groups A, B, C, and D**

**Class II, Division 1, Groups E, F, G** (except Pressure Format G)

**Class III** (except Pressure Format G)

**Enclosure Type 4, Dual Seal** (except Pressure Format G)

Temperature Code T4 at Ta = 80°C

Temperature Code T5 at Ta= 40°C

When installed per the following drawings:

[CD0627](#) 570, 571, 572, 584

[CD0637](#) 970

This is specified on the CSA Certificate of Compliance [1000784](#)

The products are marked with the CSA Mark and the above ratings

I declare that the above statements are factual.

Joel Neri

Quality/Approvals Manager

4/9/2021

Date