



199 Fire Tower Dr
Tonawanda NY 14150 USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the NY option:

548, 570, 571,572, 584, 748, 770, 771, 848, 870, 948, 970, LP748, and LP 770

Were evaluated by:

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062, USA

They were found to comply with the following United States Regulations:

FM Class 3600: 2018
FM Class 3615: 2022
FM Class 3810: 2022
ANSI/ISA 61010-1:2015
ANSI/ISA-60079-0:2019
ANSI/UL-60079-1:2015
ANSI/ISA-12.27.01:2011
ANSI/NEMA 250:2003

This shows that these products are rated Explosionproof and can be used in the following Hazardous Locations:

Class I, Division 1, Groups A, B, C, and D

This shows that these products are rated Flameproof (models with G or V format or TB option code not zone rated) and can be used in the following Hazardous Locations:

Class I, Zone 1, AEx db IIC

This shows that these products are rated Dust-ignition-proof and can be used in the following Hazardous Locations:

Class II/III, Division 1, Groups E, F, and G


Temperature Code T5 Ta= 88°C

Dual Seal, NEMA Type 4X (Indoor/Outdoor)

This is specified on the FM Certificate of Compliance [FM18US0096](#)

The products are marked with the FM Mark and the above ratings

I declare that the above statements are factual.



Joel Neri
Quality/Approvals Manager

6/14/2022
Date