



3829 Forest Parkway, Suite 500
Wheatfield, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the NY option:

548, 570, 571, 572, 584, 748, 770, 771, 848, 870, 948, 970, LP748, and LP 770

Were evaluated by:

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062, USA

They were found to comply with the following United States Regulations:

Approval Standard Class No 3600: 1998
Approval Standard Class No. 3615: 1989
Approval Standard Class No. 3810: 2005
ANSI/ISA-S12.0.01:1998
ANSI/ISA-S12.22.01:1998
ANSI/NEMA 250: 2003
ISA-12.27.01

This shows that these products are rated Explosionproof and can be used in the following Hazardous Locations:

Class I, Division 1, Groups A, B, C, and D

This shows that these products are rated flameproof and can be used in the following Hazardous Locations:

Class I, Zone 1, AEx d IIC

This shows that these products are rated dust-ignitionproof and can be used in the following Hazardous Locations:

Class II/III, Division 1, Groups E, F, and G

Temperature Code T5 in an ambient of 88°C or less
Dual Seal, NEMA Type 4X (Indoor/Outdoor)

This is specified on the FM Certificate of Compliance [3000882](#)

The products are marked with the FM Mark and the above ratings

I declare that the above statements are factual.

Bruce R. Temple
Certification/Regulation Lead