



199 Fire Tower Drive
Tonawanda, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the NZ option:

511, 512, and 513

Were evaluated by:

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062, USA

They were found to comply with the following United States Regulations:

FM Class 3600: 2011	ANSI/UL 60079-0: 2013
FM Class 3610: 2010	ANSI/UL 60079-11: 2014
FM Class 3611: 2004	ANSI/ISA 60079-15: 2013
FM Class 3810: 2005	ANSI/ISA 61010-1: 2004
ANSI/NEMA 250: 2003	ANSI/IEC 60529: 2004

This shows that these products are Nonincendive and can be used in the following Hazardous Locations:

Class I, Division 2, Groups A, B, C, and D

Class I, Zone 2, AEx nA IIC

Temperature Code T4 Ta = -40°C to 85°C

Temperature Code T5 Ta = -40°C to 40°C

When installed per the following drawings:


[CD0673](#)

Enclosure rating of NEMA Type 6P and IP68

This is specified on the FM Certificate of Compliance [FM16US0258X](#)

The products are marked with the FM Mark and the above ratings

I declare that the above statements are factual.



Joel Neri
Viatran Engineering Manager

4/11/2018
Date