



3829 Forest Parkway, Suite 500
Wheatfield, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the TF option:

709

Were evaluated by:

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062, USA

They were found to comply with the following United States Regulations:

Approval Standard Class No 3600: 1998
Approval Standard Class No. 3610:1999
Approval Standard Class No. 3810: 1989

This shows that these products are Intrinsically Safe and can be used in the following Hazardous Locations:

Class I, Division 1, Groups A, B, C, D

Class I, Zone 0 AEx ia IIC

Temperature Code T4 in an ambient of 80°C or less

When installed per the following drawings:

[CD0644](#)

This is specified on the FM Certificate of Compliance [3019330](#)

The products are marked with the FM Mark and the above ratings

I declare that the above statements are factual.

Bruce R. Temple
Certification/Regulation Lead