



199 Fire Tower Drive
Tonawanda, NY USA

Phone: (716) 629-3800
FAX: (716) 693-9162



Certificate of Compliance

The following models, with the TG option:

511, 512, and 513

Were evaluated by:

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062, USA

They were found to comply with the following standards:

CSA- C22.2 No. 213: M1987 (R2013)	FM Class 3600: 2018
CSA-C22.2 No. 157: 92 (R2012)	FM Class 3610: 2010
CSA- C22.2 1010-1: 2004	FM Class 3611: 2004
CAN/CSA- C22.2 No. 60079-0: 2011	FM Class 3810: 2005
CAN/CSA- C22.2 No. 60079-11: 2014	ANSI/UL 61010-1: 2004
CAN/CSA-C22.2 No. 60079-15:2012	ANSI/UL 60079-0: 2013
CSA- C22.2 No. 94-M91 (R2011)	ANSI/UL 60079-11: 2014
CSA- C22.2 No. EN60529: R2010	ANSI/ISA 60079-15: 2013
	ANSI/NEMA 250: 2003
	ANSI/IEC 60529: 2004

This shows that these products are Intrinsically Safe and can be used in the following Hazardous Locations:

Class I, Division 1, Groups A, B, C, and D

Class I, Zone 0 Ex ia IIC

Temperature Code T4 Ta = -40°C to 85°C

Temperature Code T5 Ta = -40°C to 40°C

Enclosure Type 6P, IP68

When installed per the following drawings:

[CD0671](#)

This is specified on the FM Certificate of Compliance [FM16CA0133X](#) and [FM16US0258X](#)

The products are marked with the FM Mark and the above ratings

I declare that the above statements are factual.



Joel Neri
Viatran Quality/Approvals Manager

4/20/2021

Date